



St. Johns County Utility Department
Wastewater Pump Station Startup Report

GENERAL INFORMATION

STARTUP DATE _____ P.S. # _____ ASBUILT# _____ ZONE# _____
 DEVELOPMENT NAME _____
 ADDRESS _____
 ENGINEER _____ CONTRACTOR _____

GENERAL SITE REQUIREMENTS

- MIN. 1" WATER SERVICE
- POSITIVE DRAINAGE
- PRIVACY SLATS
- HOSE BIB WITH BACKFLOW PREVENTER
- STATIC WATER LINE
- SITE LIGHTING
- FENCE
- DRIVEWAY & PAD

ELECTRICAL & CONTROLS

ELECTER METER CAN # _____

VOLTAGE _____ SINGLE PHASE THREE PHASE

GEN.RECEPT.MANUF. _____ MODEL# _____

CIRCUIT BREAKERS

	MANUFACTURE	AMPS
MAIN	_____	_____
EMERGENCY	_____	_____
PUMP	_____	_____

PUMP STARTER

MANUF _____ MODEL # _____ NEMA SIZE _____

CONTROL CABINET

- STAINLESS
- ALARM LIGHT
- RIGID SERVICE CONDUIT
- MAIN / EMERG. MECH. INTERLOCK
- GROUND ROD
- ALARM HORN
- STATION GROUNDED
- WIRING DIAG.
- 3 POINT LATCH
- SILENCE BUTTON
- SS NEMA 4X ENCLOSURE
- DRIP SHIELD

WATER LEVEL CONTROLS

Wet Well Pressure Transducer YES No

Transducer levels

Pump off Elev. _____ Act. Design Lag Pump On Elev. _____ Act. Design
 Lead Pump On Elev. _____ Act. Design High Level Alarm _____ Act. Design

